

Be15 model: be 15 kindegarden

Date 8.01.2017 19.27

Ny Dyginstitution i Kragelund	
BBR-no	
Owner	
Address	
The building	
Building type	Other
Rotation	356.0 deg
Area of heated floor	624.0 m ²
Area heated basement	0.0 m ²
Area existing / other usage	0.0 m ²
Heated gross area incl. basement	624.0 m ²
Heat capacity	120.0 Wh/K m ²
Normal usage time	45 hours/week
Usage time, start at - end at, time	7 - 16
Calculation rules	
Calculation rules	BR: Actual conditions
Supplement to energy frame	0.0 kWh/m ² år
Heat supply and cooling	
Basic heat supply	District heating
Electric panels	No
Wood stoves, gas radiators etc.	No
Solar heating plant	No
Heat pumps	No
Solar cells	Yes
Wind mills	No
Mechanical cooling	No
Room temperatures, set points	
Heating	20.0 °C
Wanted	23.0 °C
Natural ventilation	24.0 °C
Mechanical cooling	25.0 °C

Room temperatures, set points	
Heating store	15.0 °C
Dimensioning temperatures	
Room temp.	20.0 °C
Outdoor temp.	-12.0 °C
Room temp. store	15.0 °C

External walls, roofs and floors					
Building component	Area (m ²)	U (W/m ² K)	b	Dim.Inside (C)	Dim.Outside (C)
External wall	226.2	0.15	1.000	20	-12
External wall next to unheated rooms	74.0	0.15	0.700	20	-12
Flat roof	652.0	0.10	1.000	20	-12
Traingle roof	78.0	0.10	1.000	20	-12
Skylight roof	63.6	0.10	1.000	20	-12
Ground floor slab with floor heating	552.2	0.10	1.000	30	10
Ground fæppr slab at the entrance	8.5	0.10	0.700	30	10
Ground floor slab in unheated rooms	69.8	0.10	0.700	30	10
Ialt	1724.3	-	-	-	-

Foundations etc.					
Building component	l (m)	Loss (W/mK)	b	Dim.Inside (C)	Dim.Outside (C)
External wall foundation	213.3	0.13	1.000	20	-12
Joints at windows and doors	120.0	0.03	1.000		-12
	0.0	0.00	0.000		
	0.0	0.00	0.000		
	0.0	0.00	0.000		
Ialt	333.3	-	-	-	-

Windows and outer doors													
Building component	Number	Orient	Inclination	Area (m ²)	U (W/m ² K)	b	Ff (-)	g (-)	Shading	Fc (-)	Dim.Inside (C)	Dim.Outside (C)	Ext
Window on north site 700*700	5	N	90.0	2.3	0.70	1.000	0.70	0.47	Window 700*700 n	0.77	20	-12	0
Window on north site 1000*1000	3	N	90.0	4.0	0.70	1.000	0.70	0.47	Window 1000*1000 s	0.77	20	-12	0

Windows and outer doors													
Window on north site 1500*1500	1	N	90.0	2.1	0.70	1.000	0.70	0.47	Window 1500*1500 s	0.77	20	-12	0
Window on north site with door 1200*2145	3	N	90.0	13.5	0.70	1.000	0.70	0.47	Window with door	0.77	20	-12	0
Door on north site	1	N	90.0	1.7	0.70	1.000	0.70	0.47	Window with door	0.77	20	-12	0
Window on east site 700*700	1	E	90.0	0.5	0.70	1.000	0.70	0.47	Window 700*700 s	0.77	20	-12	0
Window on east stie 1000*1000	2	E	90.0	2.0	0.70	1.000	0.70	0.47	Window 1000*1000 s	0.77	20	-12	0
Window on east stie with door	1	E	90.0	4.5	0.70	1.000	0.70	0.47	Window with door	0.77	20	-12	0
Door on east stite 912*2145	1	E	90.0	1.9	0.70	1.000	0.70	0.47	Window with door	0.77	20	-12	0
	1	E	90.0	0.0	0.70	1.000	0.70	0.47	Glass facade	0.70	20	-12	0
Window on south site 700*700	2	S	90.0	1.0	0.70	1.000	0.70	0.47	Window 700*700 s	0.77	20	-12	0
Window on south site 1000*1000	3	S	90.0	3.0	0.70	1.000	0.70	0.47	Window 1000*1000 s	0.77	20	-12	0
Window with door 1200*2145	1	S	90.0	1.7	0.70	1.000	0.70	0.47	Window 1500*1500 s	0.77	20	-12	0
	0		0.0	0.0	0.00	0.000	0.00	0.47	Window with door	0.00			0
Glass facade on south site	1	S	90.0	55.0	0.70	1.000	0.70	0.47	Glass facade	0.77	20	-12	0
Window on vest site 700*700	1	V	90.0	0.5	0.70	1.000	0.70	0.25	Window 700*700 s	0.77	20	-12	0
Window on vest site 1000*1000	1	V	90.0	1.0	0.70	1.000	0.70	0.47	Window 1000*1000 s	0.77	20	-12	0
Window on vest site 1500*1500	2	V	90.0	4.5	0.70	1.000	0.70	0.47	Window 1000*1000 s	0.77	20	-12	0

Windows and outer doors													
Skylight	4	S	45.0	38.0	0.70	1.000	0.70	0.25	Glass facade	0.77	20	-12	0
	1	V	90.0	0.0	0.00	1.000	0.70	0.47	Glass facade	0.77	20	-12	0
Ialt	35	-	-	309.1	-	-	-	-	-	-	-	-	-

Shading					
Description	Horizon (°)	Eaves (°)	Left (°)	Right (°)	Window opening (%)
Glass facade	0	55	0	0	10
Window 700*700 s	0	55	0	0	10
Window 1000*1000 s	15	55	0	0	10
Window 1500*1500 s	15	55	0	0	10
Window with door	15	55	0	0	10
Window 700*700 n	15	55	0	0	10

Summer comfort	
Floor area	0.0 m ²
Ventilation, winther	0.0 l/s m ²
Ventilation, summer, 9-16	0.0 l/s m ²
Ventilation, summer, 17-24	0.0 l/s m ²
Ventilation, summer, 0-8	0.6 l/s m ²

Ventilation													
Zone	Area (m ²)	F _o , -	q _m (l/s m ²), Winter	n vgv (-)	t _i (°C)	El-HC	q _n (l/s m ²), Winter	q _{i,n} (l/s m ²), Winter	SEL (kJ/m ³)	q _{m,s} (l/s m ²), Summer	q _{n,s} (l/s m ²), Summer	q _{m,n} (l/s m ²), Night	q _{n,n} (l/s m ²), Night
Mechanical ventilation 1	38.0	0.70	1.77	0.90	18.0	No	0.13	0.09	1.8	1.77	0.13	0.00	0.09
Mechanical ventilation 2	11.0	0.70	1.89	0.90	18.0	No	0.13	0.09	1.8	1.89	0.13	0.00	0.09
Mechanical ventilation 3	11.0	0.70	1.89	0.90	18.0	No	0.13	0.09	1.8	1.89	0.13	0.00	0.09
Mechanical ventilation 4	22.0	0.70	1.75	0.90	18.0	No	0.13	0.09	1.8	1.75	0.13	0.00	0.09
Mechanical ventilation 5	52.0	0.70	1.71	0.90	18.0	No	0.13	0.09	1.8	1.71	0.13	0.00	0.09
Mechanical ventilation 6	0.0	0.00	0.00	0.90	0.0	No	0.00	0.00	0.0	0.00	0.00	0.00	0.00
Mechanical ventilation 7	40.0	0.70	1.70	0.90	18.0	No	0.13	0.09	1.8	1.70	0.13	0.00	0.09

Ventilation													
Mechanical ventilation 8	31.0	0.70	1.64	0.90	18.0	No	0.13	0.09	1.8	1.64	0.13	0.00	0.09
Mechanical ventilation 9	60.0	0.70	2.55	0.90	18.0	No	0.13	0.09	1.8	2.50	0.13	0.00	0.09
Mechanical ventilation 10	17.0	0.70	1.70	0.90	18.0	No	0.13	0.09	1.8	1.70	0.13	0.00	0.09
Mechanical ventilation 11	40.0	0.70	1.82	0.90	18.0	No	0.13	0.09	1.8	1.82	0.13	0.00	0.09
Mechanical ventilation 12	18.0	0.70	1.62	0.90	18.0	No	0.13	0.09	1.8	1.62	0.13	0.00	0.09
Mechanical ventilation 14	44.0	0.70	1.82	0.90	18.0	No	0.13	0.09	1.8	1.82	0.13	0.00	0.09
Mechanical ventilation 15	64.0	0.70	1.72	0.90	18.0	No	0.13	0.09	1.8	1.72	0.13	0.00	0.09
Mechanical ventilation 16	26.0	0.70	1.69	0.90	18.0	No	0.13	0.09	1.8	1.69	0.13	0.00	0.09

Internal heat supply				
Zone	Area (m ²)	Persons (W/m ²)	App. (W/m ²)	App,night (W/m ²)
Whole building	624	1.5	3.5	0.0
	0	0.0	0.0	0.0
	0	0.0	0.0	0.0
	0	0.0	0.0	0.0
	0	0.0	0.0	0.0

Lighting												
Zone	Area (m ²)	General (W/m ²)	General (W/m ²)	Lighting (lux)	DF (%)	Control (U, M, A, K)	Fo (-)	Work (W/m ²)	Other (W/m ²)	Stand-by (W/m ²)	Night (W/m ²)	
Building	624.0	1.0	2.0	200	3.00	M	0.90	1.0	0.0	0.0	0.0	
Kontorer mv. langs bagvæg	0.0	0.0	0.0	0	0.00	K	0.00	0.0	0.0	0.0	0.0	
Reception og venteområde, langs facade	0.0	0.0	0.0	0	0.00	K	0.00	0.0	0.0	0.0	0.0	
Gangareal	0.0	0.0	0.0	0	0.00	U	0.00	0.0	0.0	0.0	0.0	
Toiletter	0.0	0.0	0.0	0	0.00	A	0.00	0.0	0.0	0.0	0.0	

Other el. consumption	
Outdoor lighting	0.0 W
Spec. apparatus, during service	0.0 W
Spec. apparatus, always	0.0 W

Basement car parkings etc.											
Zone	Area (m ²)	General (W/m ²)	General (W/m ²)	Lighting (lux)	DF (%)	Control (U, M, A, K)	Fo (-)	Work (W/m ²)	Other (W/m ²)	Stand-by (W/m ²)	Night (W/m ²)

Mechanical cooling	
Description	Mekanisk køling
Share of floor area	0
El-demand	0.50 kWh-el/kWh-cool
Heat-demand	0.00 kWh-heat/kWh-cool
Load factor	0
Heat capacity phase shift (cooling)	0 Wh/m ²
Increase factor	1.50
Documentation	

Heat distribution plant					
Composition and temperature					
Supply pipe temperature	60.0 °C				
Return pipe temperature	45.0 °C				
Type of plant	2-string		Anlægstype		
Pumps					
Pump type	Description	Number	P _{nom}	F _p	
Constant service all year		1	0.0 W	0.00	
Constant service during heating season		1	0.0 W	0.00	
Time-controlled service during heating season	Behovsstyret pumpe	1	75.0 W	0.60	
Combi-pump (const. during heating season)		1	0.0 W	0.00	
Heating pipes					
Pipe lengths in supply and return	l (m)	Loss (W/mK)	b	Outdoor comp (J/N)	Unused summer (J/N)

Domestic hot water	
Description	Varmt brugsvand
Hot-water consumption, average for the building	100.0 litre/year per m ² of floor area
Domestic hot water temp.	55.0 °C
Hot-water tank	
Description	VBV Beholder

Hot-water tank	
Number of hot-water containers	1.0
Tank volume	150.0 liter
Supply temperature from central heating	70.0 °C
El. heating of DHW	No
Solar heat tank with heating coil	No
Heat loss from hot-water tank	2.3 W/K
Temp. factor for setup room	0.0

Charging pump	
Effect	50.0 W
Controlled	Yes
Charge effect	10.0 kW

Heat loss from connector pipe to DHW tank			
Length	Loss	b	Description
2.0 m	0.2 W/K	0.00	Varmerør 1"
0.0 m	0.0 W/K	0.00	

Circulating pump for DHW	
Description	PumpCirc
Number	1.0
Effect	0.0 W
Number	0.0
Effect	0.0 W
Reduction factor	1.00 W
El. tracing of discharge water pipe	No

Domestic hot water discharge pipes			
Pipe lengths in supply and return	l (m)	Loss (W/mK)	b
	0.0	0.00	0.000

Water heaters	
Electric water heater	
Description	Elvandvarmer
Share of DHW in separate el. water heaters	0.0

Electric water heater	
Heat loss from hot-water tank	0.0 W/K
Temp. factor for setup room	0.00
Gas water heater	
Description	Gasvandvarmer
Share of DHW in separate gas water heaters	0.0
Heat loss from hot-water tank	0.0 W/K
Efficiency	0.0
Pilot flame	0.0 W
Temp. factor for setup room	0.00

Boiler				
Description	God kondenserende gaskedel			
Fuel	Gas			
Number of boilers	1			
Nominal effect	28.0 kW			
Share of nominal effect for DHW production, -	1.0			
Nominal efficiencies				
Type	Load	Efficiency	Boiler temp.	Correction
Full load	1.0	0.96	70.0 °C	0.001 -/°C
Partial load	0.3	1.05	35.0 °C	0.001 -/°C
Idle loss				
Type	Load	Loss factor	Share for room	Temp. dif.
Idle	0.0	0.005	0.75	30.0 °C
Operating				
Boiler temp., min	0.0 °C			
Temp. factor for setup room	0.00			
Fan	150.0 W			
El for automatics	7.0 W			

District heat exchanger	
Description	Ny fjernvarmeveksler
Nominal effect	55.0 kW

District heat exchanger	
Heat loss	1.2 W/K
DHW heating through exchanger	No
Exchanger temperature, min	0.0 °C
Temp. factor for setup room	0.00
Automatics, stand-by	0.0 W

Other room heating	
Direct el for room heating	
Description	Supplerende direkte rumopvarmning
Share of floor area	0.0
Wood stoves, gas radiators etc.	
Description	
Share of floor area	0.0
Efficiency	0.0
Air flow requirement	0.0 m ³ /s

Solar heating plant		
Description	Nyt solvarmeanlæg	
Type	Domestic hot water	
Solar collector		
Area 0.0 m ²	Start 0.8	-
Coefficient of heat loss a1 3.5 W/m ² K	Coefficient of heat loss a2 0.0 W/m ² K	Anglefactor 0.0
Orientation	Slope 0.0 °	-
Horizon 0.0 °	Left 0.0 °	Right 0.0 °
Solar collector pipe		
Length 0.0 m	Heat loss 0.00 W/mK	Circuit 0.8
Electricity		
Pump in solar collector circuit 0.0 W	Automatics, stand-by 0.0 W	

Heat pumps	
Description	Ny varmpumpe
Type	Domestic hot water
Share of heating requirement	0.0
El. driven heat pump	

-	Room heating	DHW
Nominal effect	0.0 kW	0.0 kW
Nominal COP	0.00	0.00
Rel. COP at 50% load	0.00	0.00

Test temperatures

-	Room heating	DHW
Cold side	0.0 °C	0.0 °C
Warm side	0.0 °C	0.0 °C

Type

-	Room heating	DHW
Cold side	Earth hose	Earth hose
Warm side	Room air	-

Additional

-	Room heating	DHW
Special auxiliary tool	0.0 W	0.0 W
Automatics, stand-by	0.0 W	0.0 W

Heat pumps connected with ventilation

-	Room heating	DHW
Temp. Efficiency for HRV before heat pump	0.00	0.00
Dim. air supply temperature	0.0 °C	-
Air flow requirement	0.00 m ³ /s	0.00 m ³ /s

Solar cells

Description	Solar cells on traingle roof	
-------------	------------------------------	--

Solar cells

Area 39.0 m ²	Orientation S	Slope 45.0 °
Horizon 0.0 °	Left 0.0 °	Right 0.0 °

Additional

Peak power 0.180 kW/m ²	Efficiency 0.96
------------------------------------	-----------------